



Certificate of
constancy of performance
0560-CPR-172190054
Issue: 00

Issued	28 September 2018	Replaces	
First issued	28 September 2018	Page	1 of 2

In compliance with Regulation 305/2011/EU of the European Parliament and of the Council of 9 March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product:

Product description:	Supervised Premises Transceiver
Trademark:	ipTNA
Type designation:	V2.04
Hardware / Software version:	V2.04c / R64
Conditions and essential characteristics:	See Annex 1
Variants:	See Annex 1

placed on the market under the name or trademark of:

Name:	Com One Austria GmbH
Address:	Talpagasse 1a
City:	1230 WIEN
Country:	Austria

and produced in the manufacturing plant(s):

Manufacturer:	Com One Austria GmbH
Address:	Talpagasse 1a
City:	1230 WIEN
Country:	Austria

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard(s):

EN 54-21	June, 2006
EN 54-4	1997

under system 1 for the performances set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure the **constancy of performance of the construction product**.

This certificate was first issued on 2018-09-28 and will remain valid as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.

Petrouchka Kaasenbrood

CERTIFICATE

Remarks and observations

The following conditions are applicable:

Product category: Supervised Premises Transceiver

Equipment class: Fixed

Type: 1 (LAN/GPRS)

Relevant clauses EN 54-21:

Essential characteristics Clauses in this European Standard

Performance of transmission 4, 5

Operational reliability 4, 5, 7, 8, 9

Durability of operational reliability,

Temperature resistance 10.4

Durability of operational reliability,

Vibration resistance 10.6, 10.7,10.11

Durability of operational reliability,

Electrical stability 10.8, 10.9

Durability of operational reliability,

Humidity resistance 10.5, 10.10

Relevant clauses EN 54-4:

Essential characteristics Clauses in this European Standard

Performance under fire condition 4, 5, 6

Operational reliability 4, 5, 6, 7, 8, 9.3

Durability of operational reliability,

Temperature resistance 9.5, 9.6

Durability of operational reliability,

Vibration resistance 9.7, 9.8, 9.15

Durability of operational reliability,

Electrical stability 9.9 to 9.13

Durability of operational reliability,

Humidity resistance 9.6, 9.14

The product as described in this Certificate of Constancy of Performance includes the following type designations:

- | | |
|------------------------|---------------------------------|
| - Product description: | Supervised Premises Transceiver |
| - Trademark: | ipTNA |
| - Type designation: | V2.04 |
| - Hardware version: | V2.04c |
| - Software version: | R64 |